

	<u>Circulation water</u>	<u>make up water</u>
EC (25 /cm)	8000 ~ 14000	3400 ~ 6000
TDS(mg/L)	6000 ~ 9500	2800 ~ 4500
Total hardness (mg/l. as CaCO ₃)	1400 ~ 2200	800 ~ 1100
TBC (Bact/ml)	10 ³ ~ 10 ⁴	10 ³

NALCO Chemical

1- 7356 = 242 T/year for both Cooling Tower

2- 23203 = 242 T/year for both Cooling Tower

3- 8514 = 27 T/year for both Cooling Tower

4- 7348 = 9 T/year for both Cooling Tower

Payment : By Iraqi Germany Protocol " BY EURO "

C.D. : 11 / 9 / 2002

origin : Germany

(XLS 198)